

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. Nil .

Dated: 22/4/26

It is certified that an inspection team headed by ..... NEHA KUMARI .....  
 (Name of Officers with designation) from ..... SANITATION OFFICER, NAGAR PARISHAD, SEPUR .....  
 (Name of Department/ Office) inspected the ..... GAYATRI SHEKSHA NIKETAN HIGH SCHOOL .....  
 (Name & Address of the school) on 22/4/26 ..... (date of inspection) and found that  
 the GAYATRI SHEKSHA NIKETAN HIGH SCHOOL (Name of school) has safe drinking water facilities  
 for the students and members of staff of the institution and is maintaining the hygienic sanitation  
 condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.  
 The above is valid for a period of ... ONE ... YEAR ..

Signature with Seal:  22/4/26

Name

: NEHA KUMARI .....

Designation

: A.P.S.W.M.O. ....

Name & Address of the Office / Department : UDHD, Nagar  
Parishad, Simri Bakhtiyarpur

To

GAYATRI SHEKSHA NIKETAN HIGH SCHOOL  
 NEPAL ROAD, SIMRI BAKHTIYARPUR, SAHARSA

(Name &amp; Address of the Institution)

\* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language,  
 translated notarized version in English be uploaded along with the original vernacular certificate as a  
 single pdf.

**Government of Bihar**  
Public Health Engineering Department

Water Quality Test Report

Name of Laboratory : DLWTL,Saharsa		Division Name:- PH Division Saharsa		Sample Collected By: Beneficiary		Physico - Chemical and Bacteriological Parameters										Sampling Date : 21.04.2026,	
Date Of Testing: 22.04.2026																	
SL. No.	Name of Nearest Person/Location	Type Of Source	pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka.	NO3	F	Fe	Bacteriology by(H2S vial)	Remarks	
1	Gayatri Shiksha Niketan High School, Simribakhtiyarpur	Treated Water	7.54	0.06	464	290	150	30	15	40	160	BDL	0.3	0.1	-Ve	Safe	
	Unit		-	NTU	µmho/cm	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l			
	Desirable Limit*		6.5	1.0	-	500	200	75	30	250	200	45	1.0	1.0	-	-	
	Permissible Limit* in absence of alternate source as per BIS:10500		8.5	5.0	-	2000	600	200	100	1000	600	NR	1.5	NR	-	-	

Note:-BDL: Means Below Detection Limit & NR: Means Not Relaxation.

*AB*  
22/04/26

**Chemist**  
D.L.W.T. Lab.  
Saharsa